



OFFICE OF THE  
TELIAMURA MUNICIPAL COUNCIL  
TELIAMURA: KHOWAI, TRIPURA

Ph. 03825-354-585

✉teliamuranp@gmail.com

## **SANITARY CERTIFICATE**

**Reference: Letter No. F.1(1)/Principal/THss/2024/705, dated 03/09/2026, received from the Principal, Teliamura H.S. School, Teliamura.**

This is to certify that **Teliamura H.S. School**, Teliamura, Khowai, Tripura, situated within the jurisdiction of Teliamura Municipal Council, has been inspected with regard to the sanitation and cleanliness arrangements available in the school premises.

Based on the inspection and the sanitation facilities maintained therein, the sanitation arrangements of the school are found to be satisfactory and conducive to maintaining proper hygiene and cleanliness.

***This certificate is issued with reference to the letter cited above.***

Digitally signed by  
Pradip Kumar Sarkar  
Date: 10-09-2026  
15:06:20

**Dy. Chief Executive Officer  
Teliamura Municipal Council**



**Scanner AI Pro**

GOVERNMENT OF TRIPURA  
OFFICE OF THE SUB DIVISIONAL MEDICAL OFFICER  
TELIAMURA, KHOWAI TRIPURA

NO.F.2 (18)-SDMO/TLM/GEN/2020/2720

Dated, Teliamura, the 08 / 09 / 2026.

**TO WHOM IT MAY CONCERN**

This is to certify that periodic health check-ups of the students of Teliamura H.S School, Khowai, Tripura is conducted regularly by Teliamura Subdivisional Hospital

The health check-ups include general health assessment, screening for common ailments, monitoring of students health conditions, and referral of students requiring further medical evaluation and treatment at appropriate healthcare facilities whenever necessary.

It is further certified that necessary medical support and guidance are provided to the institution for ensuring good health and well-being of its students.

This certificate is issued on the request of the principal, Teliamura H.S School Teliamura, for official purpose.

To  
The Principal  
Teliamura H.S School Khowai, Tripura

  
Sub Divisional Medical Officer  
Teliamura Sub Divisional Hospital  
Teliamura  
Khowai Tripura  
Sub-Divisional Medical Officer  
Teliamura, Khowai, Tripura.



Scanner AI Pro



Sub-Division Level  
Water Testing Laboratory  
DWS Sub-Division, Teliamura  
Khowai Tripura.

| Sl. No. | Source of Sample                                  | Date of Collect | Date of Testing | Results         |     |            |                       |             | Remarks                                                                                                                  |
|---------|---------------------------------------------------|-----------------|-----------------|-----------------|-----|------------|-----------------------|-------------|--------------------------------------------------------------------------------------------------------------------------|
|         |                                                   |                 |                 | Turbidity (NTU) | pH  | TDS (mg/L) | Total Hardness (mg/L) | Iron (mg/L) |                                                                                                                          |
| 1.      | TELAMURA H.S. SCHOOL<br>TELAMURA, KHOWAI TRIPURA. | 03/09/2026      | 09/09/2026      | 0.5             | 6.9 | 83         | 94                    | 0.24        | Permissible Limits :-<br>pH:- 6.5-8.5<br>Turbidity:- 5 mg/l<br>Hardness:- 200-600mg/l<br>Iron:- 1.0mg/l<br>TDS:- 500mg/l |

Sr. Research Assistant  
DWS sub-Division, Teliamura  
Khowai Tripura

09/09/26

Assistant Engineer  
DWS sub-Division, Teliamura  
Khowai Tripura

09/09/26

### Water Testing Report