

Sub-Division Level
Water Testing Laboratory
DWS Sub-Division, Teliamura
Khowai Tripura.

Water Testing Report									
Sl. No.	Source of Sample	Date of Collect	Date of Testing	Results					Remarks
				Turbidity (NTU)	pH	TDS (mg/L)	Total Hardness (mg/L)	Iron (mg/L)	
1.	TELIAMURA H.S SCHOOL TELIAMURA, KHOWAI TRIPURA.	03/09/2026	09/09/2026	0.5	6.9	83	94	0.24	Permissible Limits :- pH:- 6.5-8.5 Turbidity:-5 mg/l Total Hardness:-200-600mg/l Iron:-1.0mg/l TDS:-500mg/l

[Signature]

Sr. Research Assistant
DWS sub-Division, Teliamura
Khowai Tripura

[Signature]
Assistant Engineer
DWS sub-Division, Teliamura
Khowai Tripura